



GRADED AGGREGATE FOR BITUMINOUS SURFACE FIELD SECTION 1004

1004.1 SCOPE. To establish procedures for the inspection and acceptance of graded aggregate for bituminous surface.

1004.2 PROCEDURE. Inspection, testing, and sampling will be governed by the instructions contained in [Field Sec 1001](#) of this Manual.

1004.2.1 Field tests required are as follows:

- (a) Sieve analysis.
- (b) Percent deleterious substances.

1004.2.2 Samples required for Laboratory tests are as follows:

- (a) Source approval.
- (b) Production samples at the discretion of the District.

1004.3 ACCEPTANCE. Acceptance is based on routine tests in the field to insure compliance with Specification Sec 1004.

1004.4 RECORDS AND REPORTS. All plant records shown in [Field Sec 1001.6](#) of this Manual shall be maintained. The aggregates shall be reported through SiteManager in accordance with [Automation Section AS-3510](#) of this Manual.